



2012000238Z



(2012)国认监认字(144)号



TESTING  
CNAS L1314

# 检 验 报 告

## TEST REPORT

No. WT-2014-004

产品名称: Axminster Carpet

Product name

受检单位: Zhejiang Artistic Carpets Manufacturing Co.,Ltd

Inspected Body

生产单位: Zhejiang Artistic Carpets Manufacturing Co.,Ltd

Manufacturer

委托单位: Zhejiang Artistic Carpets Manufacturing Co.,Ltd

Client Name

检验类别: Entrusted Test

Kind of Test

国家地毯质量监督检验中心

China Carpet Quality Supervision and Inspection Center




**国家地毯质量监督检验中心**  
**China Carpet Quality Supervision and Inspection Center**  
**检验报告**  
**Test Report**

No\_WT-2014-004

page 1 of 2

产品名称 The product name	Axminster Carpet	规格型号 Specification	_____
		商标 Brand name	
委托单位 Client name	Zhejiang Artistic Carpets Manufacturing Co.,Ltd	检测类别 Testing type	Entrusted Test
生产单位 Manufacturer	Zhejiang Artistic Carpets Manufacturing Co.,Ltd	原编号 Original art No.	_____
受检单位 Inspected Body	Zhejiang Artistic Carpets Manufacturing Co.,Ltd	生产日期 Date of produce	_____
委托(生产)单位地址 Client's address	No.12, Wuzhou Road, Yuhang EDA, Hangzhou	电话 Client's Tel	0571-86244532
		邮编 Postcode	311100
抽样地点 Sampling spot	_____	样品等级 Sampling rating	_____
抽样基数 Sampling radix	_____	样品数量 Numbers of sampling	mm: 1050 × 230 mm: 90 × 250 (six pieces)
样品描述 Sampling description	Design and colour Sample is Perfect	送样日期(抽) Sample delivered date	2014.01.02
送样人(抽) Deliverer	Mail by the client	检测日期 Date of testing	2014.01.10
检测依据 Standards used in the test	GB 8624—2012 《Classification for burning behavior of building materials and products》 GB/T 11785—2005 《Reaction to fire tests for floorings-- Determination of the burning behaviour using a radiant heat source》 GB/T 8626—2007 《Test method of flammability for building materials》	检测项目 Test items	Reaction to fire-- B <sub>1</sub> (C)
检测结论 Conclusion of the test	The sample(s) has(ve) been tested for the reaction to fire-- critical heat flux, the length of burning according to GB 8624—2012 《Classification for burning behavior of building materials and products》. The test results show that the sample(s) meet(s) the specification of B <sub>1</sub> (C) class.		
备注 Remarks	The tested data are only suitable to the sample(s) delivered.		


批准:  
Approved by



审核:  
Checked by



编写:  
Recorded by



Date of the Issue: 2014.01.13

检验报告专用章

# 国家地毯质量监督检验中心

## China Carpet Quality Supervision and Inspection Center

### 检验报告

#### Test Report

No\_WT-2014-004

page 2 of 2

检测项目 Test Item	单位 Unit	标准指标 Criteria		实测数值 Practical Determined Data	结果评定 Assessment	
Reaction to fire-- the length of burning	mm	B <sub>1</sub>	C	F <sub>s</sub> ≤ 150	75	Passed
Reaction to fire-- critical heat flux	kW/m <sup>2</sup>			CHF ≥ 4.5	5.6	Passed
Before test			After test			
						
备注: Remarks						